



No.: 002-54 (rev.)

# Certification of Conformity

*Applicant:* Delta Electronics (Thailand) Public Co., Ltd.  
909 Soi 9 Moo 4, E.P.Z., Bangpoo Industrial Estate,  
Prakasa, Muang, Samutprakarn 10280, Thailand

*Manufacturer:* Same as above

*Product:* Grid - connected inverter

*Trademark:* Delta

*Type designation:* SOLIVIA 5.0 APG3

*Serial Number:* 220301001104000007


*Technical data:* 5 kW, Input 150-450 Vdc  
Output 230 Vrms, 27.2 Arms, 50/60Hz

The submitted sample of the above product has been tested for the following standard(s) and showing compliance with the criteria specified within.

<i>Standard(s)</i>	<i>Test report(s)</i>	<i>Issued by</i>
PEA Requirements and IEC 61727:2004 and IEC 62116:2008	CSSC/BOS/007 (July 11, 2011)	CES Solar Cells Testing Center, King Mongkut's University of Technology Thonburi

*Note:* This certificate should be read in conjunction with the issued test report(s) and it, in anyway, does not imply assessment of the series production of the product.

July 28, 2011

  
\_\_\_\_\_  
*Dr. Dhirayut Chenvidhya*  
Director

