



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA203067

Date of Issue: 30 November 2020

Regulatory Definition: Non-Prescribed

Product Description: PV Grid-interactive Inverter

| Additional Models | Trade Name | Rating/Marking |
|-------------------|------------|--|
| H9E | DELTA | Input (PV): Max 600Vdc, MPPT Range 50-480Vdc, Max Input Current 4 x 12A, Output (Grid): 230Vac 50Hz 36A 9000VA -25°C to 65°C, IP65, Class I |
| H8E | DELTA | Input (PV): Max 600Vdc, MPPT Range 50-480Vdc, Max Input Current 4 x 12A, Output (Grid): 230Vac 50Hz 32A 8000VA -25°C to 65°C, IP65, Class I |

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 09-12-20 203067/2a
Markings amended